

## PLANNING, DESIGN & CONSTRUCTION

Sixth Avenue and Grant Street • P.O. Box 172760 • Bozeman, Montana 59717-2760 Phone: (406) 994-5413 • Fax: (406) 994-5665

PPA No.: 20-0006

Date: 5-20-2024

# ADDENDUM NO. 1 - OUTLINE AND SUMMARY INFORMATION

Project Name: <u>Visual Communications Darkroom 135&138 Sink</u>

Replacement

Location: Montana State University - Bozeman

Owner: State of Montana, MSU - Bozeman

Plew Building 6th and Grant, PO Box 172760

Bozeman, Montana 59717-2760

To: All Plan Holders of Record

The Plans and Specification prepared by <u>Architects Alaska</u> dated <u>05-17-2024</u> shall be clarified and added as follow. The bidder proposes to perform all the following clarifications or changes. It is understood that the Base Bid shall include any modification of Work or Additional Work that may be required by reason of the following change or clarifications.

The Bidders are to acknowledge the receipt of this Addendum by inserting its number and date into their Bid Forms. Failure to acknowledge may subject the Bidder to disqualification and rejection of the bid. This Addendum forms part of the Contract Documents as if bound therein and modifies them as follows:

- 1. AMENDMENTS TO THE PROJECT MANUAL
  - a. Bid Date will Change to Tuesday May 28 at 2 pm
- 2. AMENDMENTS TO THE DRAWINGS
  - a. Sheets:

### Architectural:

- Sheet A101: Remove "owner furnished"
- Sheet A401: "BASIS OF DESIGN" Processing Sink Space and Service Requirements- Exhaust changed to 580 CFM and deleted note "Mechanical Engineer to calculate, size and confirm all Exhaust Requirements.

#### Plumbing:

- Sheet P002: The tempering valve <u>TV-1</u> changed from an electronic valve to a thermostatic mixing valve, Armstrong model 320. The Plumbing Specifications were updated. The Plumbing Pipe Schedule was updated.
- Sheet P101: A piping diagram for the tempering valve, TV-1, valve was added.

#### Mechanical:

- Sheet M002: Mechanical specifications were updated.
- Sheet M100: The damper in the 18"x12" duct serving two tables was removed and replaced with an individual damper for each table located in the 16"x8" duct. Each table shall be balanced at 580 CFM.

#### Electrical:

• Sheet E101: Power connection/circuit for <u>TV-1</u> removed.

- 3. OTHER
- a. N/A

END.